



NOTE :
 PROPERTY OWNERS RESPONSIBILITY INCLUDE
 CONNECTING BOLTS/NUTS/GASKET AND PIPING
 INTO THE PROPERTY FROM OUTLET OF SLUICE
 VALVE

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1	TAPPING BAND
1A	TEE
2	FERRULE/BALL/GATE/SLUICE VALVE SUPPLIED BY WATER CORPORATION AT OWNERS COST
2A	DIVIDE VALVE
3	PIPE & FITTINGS MUST BE WATERMARK APPROVED
TAPPING HOLE DIMENSIONS AS PER TAPPING GUIDELINES	

PROPERTY OWNER RESPONSIBILITY

PROPERTY OWNER RESPONSIBILITY

SURFACE COVER TO ACCESS SLUICE VALVES AND DIVIDE VALVE

WATER CORPORATION RESPONSIBILITY FOR MAINTENANCE

TEE INSERTION GREATER THAN 50mm (MAIN SHUT DOWN)

WATER CORPORATION RESPONSIBILITY FOR MAINTENANCE

WATER CORPORATION RESPONSIBILITY FOR MAINTENANCE

PROPERTY OWNER RESPONSIBILITY

TAPPING UNDER PRESSURE GREATER THAN 50mm

WATER CORPORATION RESPONSIBILITY FOR MAINTENANCE

PROPERTY OWNER RESPONSIBILITY

PROPERTY OWNER RESPONSIBILITY

PROPERTY OWNER RESPONSIBILITY

WATER CORPORATION RESPONSIBILITY FOR MAINTENANCE

THE USE OF CLASS 'A' RECYCLED WATER FOR FIRE FIGHTING PURPOSES MAY BE CONSIDERED SUBJECT TO SPECIFIC WATER BUSINESS REQUIREMENTS.

DIVIDE VALVE TAPPING (MULTIPLE TEE INSERTIONS GREATER THAN 50mm WITH DIVIDE VALVE)

TAPPING UNDER PRESSURE UP TO 50mm (BALL VALVE)

TAPPING UNDER PRESSURE UP TO 50mm (FERRULE & BEND)

DRAWING NUMBER:
17

SCALE:
NOT TO SCALE

DATE:
JULY 2017

PRIVATE FIRE SERVICE TAPPING CONFIGURATIONS
TYPICAL ARRANGEMENT

